

CENTRAL POWER RESEARCH INSTITUTE

TEST REPORT



CPRI

Test Report Number: 518EATDIP13S0269

Dated: 10.10.2013

Name & Address of the Customer : M/s. LORDS Engineering
No. 61/29, Nadakkerappa Industrial Estate,
2nd Stage Peenya, Viswaneedum Post,
Bangalore – 560 091

Name & Address of the Manufacturer : M/s. LORDS Engineering
No. 61/29, Nadakkerappa Industrial Estate,
2nd Stage Peenya, Viswaneedum Post,
Bangalore – 560 091

Particulars of sample tested

Condition of the sample on Receipt : New
Type : Outdoor
Designation : SS Junction Box.
Serial Number : LE / TLJB / 01
Number of samples tested : One only.
Date (s) of Test (s) : 07.10.2013 and 08.10.2013
CPRI sample code no(s) : EATDIP13S0269

Particulars of tests conducted

Test in accordance with
Standard / specification : IP 65 Category 2 Test as per IS/IEC 60529 Edition 2.1, 2001-02
Standard. Clause 13.4.
Sampling Plan : Not applicable.
Customer's requirement : 1. IP 65 Category 2 Test as per IS/IEC 60529 Edition 2.1,
2001-02 Standard. Clause 13.4.
2. Insulation Resistance Measurement at 500V DC and
Power frequency High Voltage withstand test at 2.0kV AC to
be applied for one minute between all terminals of MCB's
shorted together and the body of SS Junction Box Enclosure,
to be conducted before and after IP 65 test.
Deviations if any : -Nil-

Name of the witnessing persons

Customer's representative : Mr. Yohannan. G

Other than customer's representatives : None.


Test subcontracted with
address of the laboratory : None.

Documents constituting this report (In words)

Number of sheets : Three Only.
Number of oscillograms : -Nil-
Number of graphs : -Nil-
Number of photos : -Nil-
Number of test circuit diagrams : -Nil-
Number of drawings : Two only. Drg. No. LE / TLJB / 01, Rev. No. 00,
Sheet 01 of 01.


(GUJJALA B. BALARAM)
Test Engineer




(M. SIDDHARTHA BHATT)
Additional Director